



NOTES:

1. BENCH SHALL BE CONCRETE.
2. MANHOLE CONSTRUCTION SHALL CONFORM TO ASTM SPEC. C-478
3. WHERE STUBS ARE PROVIDED FOR FUTURE CONNECTIONS, BENCH SHALL BE SO FORMED.
4. FLEXIBLE JOINT SHALL BE KOR-N-SEAL OR EQUAL.
5. MINIMUM CONCRETE STRENGTH 28 DAYS - 4000 P.S.I..
6. PROVIDE MAXIMUM OF TWO LIFT HOLES PER SECTION. PLUG WATER-TIGHT AFTER INSTALLATION.
7. WHERE DROPS IN MANHOLES OF TWO (2) OR MORE OCCUR, A DROP MANHOLE SHALL BE CONSTRUCTED.
8. ONLY WET CAST CONCRETE MANHOLE BASE, RISER AND CONE SECTIONS SHALL BE ACCEPTED BY THE CITY.
9. CHIMNEY SEAL TO BE USED FROM CONE SECTION TO CAST IRON FRAME ON ALL NEW CONSTRUCTION.
10. A 12 GAUGE MIN. TRACER WIRE SHALL BE INSTALLED ALONG THE ENTIRE SERVICE LINE AND MADE ACCESSIBLE AT THE MANHOLE COVER.

Standard Manhole (8" - 15")
City of Waynesboro, VA



Original Date: 7/2/1999
Revision Date: 1/3/2002
03/01/2013



S-1